



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at water works Sector - 39


SAFE DRINKING WATER CERTIFICATE

(Not for legal use)

Ref. No. MCPH Lab / 2024 /995-96

Dated:- 15.03.2024

It is certified that on request of The Principal,
Govt. Model Sr. Sec. School, Sector – 26 – TM, Chandigarh, the water
sample was collected from the premises of above school on dated
12.03.2024 and the result of water sample found fit for drinking.


Sub Division Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

✓
To
The Principal,
Govt. Model Sr. Sec. School,
Sector – 26-TM, Chandigarh.





MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date : - No CMSSS/26TM/2024/935 dated 05.03.2024
Issued to : - The Principal
: - Govt. Model Sr. Sec. School
: - Sector - 26 TM, Chandigarh
Quantity of sample : - Approximate 1200 ml.
Date of Collection : - 12-03-2024
Client reference : - Sample Collected by Laboratory Staff
Packing of sample : - Sample Filled in P.P. and Glass Bottle
Source of sample : - from School tap of Govt. Model Sr. Sec. School
Sector - 26 , Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.72
2	Turbidity	< 1.0	mg/l	0.9
3	Residual Chlorine	0.2 - 0.4	mg/l	0.2
4	Total Alkalinity (as CaCO ₃)	< 200	mg/l	98
5	Total Hardness (as CaCO ₃)	< 200	mg/l	76
6	Chloride (as Cl)	< 250	mg/l	04
7	Free & Saline Ammonia	Nil	mg/l	NIL
8	Total Dissolved Solids	< 500	mg/l	136
9	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.03/2023-24/182031, dated 11.03.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/995.....

Dated:- 15.03.2024

Chemist
M.C.P.H. Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Dated :-

Endst No. MCPH/24/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.

Chemist
M.C.P.H. Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

